

DEPARTMENT : ELECTRO TECHNICAL ENGINEERING  
TELEPHONE : 021-807 4660

Enquiries : L. Laing  
Reference : 15/4/1

30 Mei 2017

Chand Environmental Consultants  
P.O. Box 238  
**PLUMSTEAD**  
7801

**Attention: Me. M. Penwarden**

Dear Sir

**CONFIRMATION OF ELECTRICITY CAPACITY FOR THE PROPOSED DEVELOPMENT:  
INDUSTRIAL PARK, CHAMPAGNE ROAD, ERF 34, WELLINGTON:**

Your request dated 15 May 2017 refers.

Drakenstein Municipality confirm that there is sufficient power available for the expansion of the Industrial Park development.

Drakenstein Municipality is currently in a process to complete the new 11KV substation that will enable a firm supply at Industrial Park of 6.5MVA. This will ensure available capacity of 3MVA for the expansion of the Industrial Park development.


Future plans for constructing a new 132/11KV substation on the North East side of the development where Eskom existing 132MV overhead lines passes the development, will have to be included in the spatial development plan to accommodate future growth in Wellington. An electrical engineering consultant will have to make contact with the Electro-Technical Department (Planning, Design and Construction Section – Chief Electrical Engineering Technician) regarding the electrical reticulation for approval.

Any existing services that need to be moved to a new position will be for the cost of the developer.

The developer will be responsible to pay network recovery cost charges for this development.

The developer is required to include measures to improve energy efficiency for this development to reduce consumption of electricity.

Yours faithfully



**W ALBERTYN Pr Cert Eng**  
**DEPUTY EXECUTIVE MANAGER: ELECTRO TECHNICAL ENGINEERING**

I:\Beplan3\Correspondence\2017\Cor190\_2017  
LL

ADDRESS ALL CORRESPONDENCE TO  
**THE MUNICIPAL MANAGER**  
BERGRIVER BOULEVARD-  
PO BOX 1, MAIN STREET, PAARL, 7622  
Telephone: +27(21) 807 4500 Fax: +27(21) 872 8054  
ceo@drakenstein.gov.za

RIG ALLE KORRESPONDENSIE AAN  
**DIE MUNISIPALE BESTUURDER**  
BERGRIVIER BOULEVARD-  
POSBUS 1, HOOFSTRAAT, PAARL, 7622  
Telefoon: +27(21) 807 4500 Faks: +27(21) 872 8054  
ceo@drakenstein.gov.za

LONKE UQHAKAMSHELELWANO  
**THE MUNICIPAL MANAGER**  
BERGRIVER BOULEVARD-  
PO BOX 1, MAIN STREET, PAARL, 7622  
Inombolo: +27(21) 807 4500 Fax Nombolo: +27(21) 872 8054  
ceo@drakenstein.gov.za